

**ADDENDUM NO. 2
TO
PLANS AND SPECIFICATIONS
FOR THE
WASTEWATER TREATMENT IMPROVEMENTS

SWEET SPRINGS, MISSOURI**

TO ALL PLAN HOLDERS:

This Addendum No. 2 shall be attached to and become part of the Contract Documents for the "WASTEWATER TREATMENT IMPROVEMENTS – SWEET SPRINGS, MISSOURI" project. The Specifications and Plans shall be changed and added to as follows:

BIDDING AND CONTRACT DOCUMENTS

1. **Bid Form, EJCDC C410:** Clarification for Bid Item #4 – the rip-rap shall be installed along the entire inside slope of the new aeration cell from elevation 685 to 689.

DRAWINGS

1. **Drawing C102 (Sheet 4/15):** Rip-rap shall be installed along the entire inside slope of the new aeration cell from elevation 685 to 689.

If you have any questions, please contact Michael Hall by email at mhall@mecresults.com or by phone at 573-814-1568.

Sincerely,

McCLURE ENGINEERING COMPANY



Michael M. Hall, P.E., M.ASCE
Senior Project Manager



Jan. 10, 2018

END OF ADDENDUM #2