



CITY OF COLUMBIA, MISSOURI

FINANCE DEPARTMENT
PURCHASING DIVISION

NOTICE TO BIDDERS ADDENDUM #1 RFQ # 64/2018

SINCLAIR CULVERT REPLACEMENT AT MILL CREEK

Bidders shall note these changes to the above Request for Quotation and *incorporate these changes in their submittal*. Bidders shall attach a signed acknowledged copy of this addendum to their bid, if submitting a hard copy (via paper) or agree to the addendum electronically if submitting through the electronic bid system on line.

The following revisions and/or additions shall be referred to as part of the Bid/Contract Documents.

General Clarifications:

- 1) The closing date listed online is March 14th whereas the printed solicitation says March 13th. Can you clarify the correct date?
The bid will close on March 13, 2018 at 2:00pm CST
- 2) The asphalt typical section on sheet 2 shows 7.5" of SP25C. Is this supposed to read SP250C?
It should read SP250. It is from the Standard Street, Storm and Sanitary Specifications.
- 3) For the 2" asphalt on rolled stone base, can you clarify the type of asphalt? Is this to be SP125 as well?
Use 1 1/2" of SP125 on rolled stone base for this.
- 4) When is the project award anticipated? The lead time for the precast unit could push the installation date very close to the date that the road must be opened, not leaving much time for installation and street replacement. How will this be addressed if the precast unit is not completed and delivered in ample time to complete construction by August 10th?
I do not anticipate a problem with the awarding of this project. A contract should be able to be turned around quickly, once the contractor has submitted the signed copies, bonding and insurance information. The Department is willing to begin review of submittals before the Notice to Proceed date. (Notice to proceed is expected in the middle of April.)

ACKNOWLEDGEMENT OF ADDENDUM #1

The undersigned Respondent hereby certifies that the changes set forth in this Addendum #1 have been incorporated in their proposal and are a part of Request for Quotation No. 64/2018 other provisions of the bid documents, except as herein stated, shall remain in force as written.

Firm _____ Date _____

Signed _____



CITY OF COLUMBIA, MISSOURI

UTILITIES DEPARTMENT
Stormwater Utility Division

Sinclair Culvert Pre-Bid Sign-in Sheet

Name	Company	phone/e-mail
Andy Baker	Emery Sapp and Sons	573-445-8331 andy.baker@emerysapp.com
Trent Bay	Don Schuellers Exc.	573-893-2251 tbay@dsecompany.com
John Kirchhoff	Lehman Co.	573-796-8101 quotes@lehmanconstructionllc.com
Scott Parry	CL Richardson	573 239 9255
Gene Haile	Gene Haile Exc. Inc.	573-796-3513 earthmover325@yahoo.com
Tedd BLACK	CONTECH	913-216-3818 tblack@conterhes.com

