

# N·FORM

## ARCHITECTURE

### Addendum #2

---

To: Blanche Kelly – Project Management – Lincoln County Missouri  
From: Jennifer Wilson  
Paden Chambers  
CC: File  
Date: May 10, 2018  
Project: Lincoln County Courthouse Exterior Renovation

---

This Addendum shall supersede the general specifications insofar as it is in disagreement with the same. However, it will in no way relieve the contractor of any responsibility under the plans and specifications except as herein specifically stated.

#### General Clarifications:

1. *Contractors Question: I am having difficulty with the specification for the fascia materials. I do not think it will be practical to use a treated hardwood. Hardwoods are so dense they do not take treatment very well. I would suggest treated Southern pine for blocking and Redwood for the fascia and moldings.*

**Architects Response: Treated southern pine for blocking and Redwood for the fascia and moldings shall be provided.**

2. *Contractors Question: I'm not sure what joist you are referring to for unit price #1. There is no joist designated on 5/A101.*

**Architects Response: Contractor is responsible for location/investigation of rotten joists after the bid.**

3. *Is the new area outlined in Addendum #1 to receive the same treatment noted in 07.001 or is this just for the paint note 07.022. Are we to make a paint recommendation prior to the bid or afterwards? Are we to include this repair/repainting in our bid?*

**Architects Response: Paint recommendations in the new area outlined in Addendum #1 are to be made after the bid. Any necessary repair and repaint work shall be performed via Change Order.**

#### Changes to the Drawings:


None.

#### Changes to the Specifications:

None.

#### Attachments:

None.



End of Addendum #2

05.10.18