

ADDENDUM NO. 2

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Replace Chillers
Administration/School Building
Missouri School for the Blind
St. Louis, Missouri
PROJECT NO. E1804-01

Bid Opening Date: 1:30 PM, Thursday, October 18, 2018 (Not Changed)

Bidders are hereby informed that the Construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. Section 230719 – HVAC Piping Insulation
 - a. REMOVE and REPLACE Paragraph 3.14-D as follows:
 - D. Piping, Exposed at Mechanical Spaces and Basement Corridors:
 1. None.
 - b. ADD new Paragraph 3.14-E as follows:
 - E. Piping, Exposed at Bowling Alley:
 1. Pre-Painted Aluminum, Smooth: 0.016 inch thick. Paint color shall be white.
 2. PVC: 20 mils (0.5 mm) thick.
2. Section 232113 – Hydronic Piping
 - a. ADD new Paragraph 2.2-E as follows:
 - E. Grooved, Mechanical-Joint Fittings are not allowed.
 - b. ADD new Paragraph 2.3-I as follows:
 - I. Grooved, Mechanical-Joint Fittings are not allowed.

DRAWING CHANGES:

1. SHEET M-001
 - a. REMOVE and REPLACE General Notes (Demolition) existing Note 3 as follows:
 3. Contractor shall take ownership of all existing equipment to be removed.
2. SHEET MD101
 - a. REMOVE AND REPLACE General Notes existing Note 2 as follows:
 2. Contractor shall take ownership of all existing equipment to be removed.

3. SHEET MD401

a. REMOVE and REPLACE General Notes existing Note 3 as follows:

3. Contractor shall take ownership of all existing equipment to be removed.

October 11, 2018

END ADDENDUM NO. 2