

BOONE COUNTY, MISSOURI
Request for Bid #: 07-14FEB19-Street Rehab-2019 EI
Chaparral Subdivision

ADDENDUM #1 - Issued February 8, 2019

This addendum is issued in accordance with the Request for Bid Notice to Bidders and is hereby incorporated into and made a part of the Request for Bid Documents. Offerors are reminded that receipt of this addendum **should** be acknowledged and submitted with Offeror's *Response Form*.

Specifications and Plans for the above noted Request for Bid and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:


1. Special Provision 201 states all asphalt mixes shall have a max of 20% Recycled Asphalt Pavement (RAP) in the mix. Mix designs for the Bituminous Base may contain RAP not to exceed 35%. Mix designs for BP-2 Surface may contain RAP not to exceed 20%. All mixes shall be MoDOT approved and be in compliance with Section 401 of the MoDOT Standard Specifications for Highway Construction.

2. Question: Will the County consider WINFAB 600 HTM geotextile an approved equal for the EI Chaparral rehab?

Answer: Yes, WINFAB 600 HTM shall be considered an approved equal.


3. Question: How shall the Sweet Gum tree and Redbud tree be handled near the proposed Alamos Stormwater (Note 2, Sheet 5)?

Answer: Property owner requested these trees not be removed. The County informed the property owner that trimming may be needed to facilitate construction. Property owner understood and was agreeable to trimming. Property owner was also warned that trees may succumb to root damage from excavation as part of the project. Property owner stated he understood the risk and would not hold the County liable in that case. However, the contractor shall coordinate with property owner prior to any trimming or work taking place on or near these trees.

By: 
Robert Wilson, Buyer
Boone County Purchasing

Approved: Micah Taylor
Professional Engineer
MO Lic. # PE-2013019123

Boone County Resource Management
MO Engineering Corp. # N/A
801 E. Walnut, Room 315
Columbia, Missouri 65201
Phone: 573-886-4480
Fax: 573-886-4340



OFFEROR has examined copy of Addendum #1 to Request for Bid # 07-14FEB19-Street Rehab 2019 El Chaparral Subdivision, receipt of which is hereby acknowledged:

Company Name: _____

Address: _____

Phone Number: _____ Fax Number: _____

Authorized Representative Signature: _____ Date: _____

Authorized Representative Printed Name: _____