

ADDENDUM NO. 1

TO: PLANS AND SPECIFICATIONS FOR STATE OF MISSOURI

Install Lethal Fence and Guard House
Western Missouri Correctional Center
Cameron, Missouri
PROJECT NO. C1926-01

Bid Opening Date: 1:30 PM, Thursday, May 2, 2019 (Not Changed)

Bidders are hereby informed that the Construction Plans and/or Specifications are modified as follows:

SPECIFICATION CHANGES:

1. SECTION 033000 – CAST-IN-PLACE CONCRETE

a. ADD Paragraph 2.12-D as follows:

D. Exterior Walls: Proportion normal-weight concrete mixture as follows:

1. Minimum Compressive Strength: 4500 psi at 28 days.
2. Minimum Cementitious Material Content: As indicated on drawings
3. Maximum Water-Cementitious Materials Ratio: As indicated on drawings
4. Slump Limit: 4 inches, plus or minus 1 inch.
5. Air Content: 6 percent, plus or minus 1.5 percent at point of delivery for 3/4-inch nominal maximum aggregate size.

2. SECTION 321313 – CONCRETE PAVING

a. REMOVE and REPACE Paragraph 2.9-F.1 as follows:

1. Compressive Strength (28 Days): 4500 psi, minimum (KCMMB-4K)

DRAWING CHANGES:

1. Drawing C-101

a. REMOVE entire sheet and REPLACE with attached revised Drawing C-101.

2. Drawing C-102

a. REMOVE entire sheet and REPLACE with attached revised Drawing C-102.

3. Drawing C-401

a. REMOVE entire sheet and REPLACE with attached revised Drawing C-401.

4. Drawing C-402

a. REMOVE entire sheet and REPLACE with attached revised Drawing C-402.

5. Drawing C-501

- a. REMOVE entire sheet and REPLACE with attached revised Drawing C-501.

6. Drawing C-502

- a. REMOVE entire sheet and REPLACE with attached revised Drawing C-502.

7. Drawing C-503

- a. REMOVE entire sheet and REPLACE with attached revised Drawing C-503.

8. Drawing C-504

- a. REMOVE entire sheet and REPLACE with attached revised Drawing C-504.

9. Drawing E-400

- a. REMOVE entire sheet and REPLACE with attached revised Drawing E-400.

10. Drawing S-001

- a. REMOVE entire sheet and REPLACE with attached revised Drawing S-001.

11. Drawing S-102

- a. REMOVE entire sheet and REPLACE with attached revised Drawing S-102.

12. Drawing T-400

- a. REMOVE entire sheet and REPLACE with attached revised Drawing T-400.

GENERAL COMMENTS:

1. The Pre-Bid Meeting is scheduled for April 18, 2019. Contractors attending this meeting must contact Randy Eaton (816-632-1390) at least 24 hours before the meeting to provide their security clearance information.
2. Please contact Kelly Copeland, Contract Specialist, at 573-522-2283 or kelly.copeland@oa.mo.gov for questions regarding bidding procedures and MBE/WBE/SDVE submittal requirements.
3. The deadline for technical questions is April 25, 2019 at noon. Submit technical questions to Mark Maurer at mark.maurer@hendersonengineers.com and copy Bryan Chinn at bryan.chinn@oa.mo.gov.
4. All correspondence with respect to this project must include the State of Missouri project number as indicated above.
5. Changes to, or clarification of, the Bid Documents are only made as issued in the Addenda.
6. Current Planholders list is available at: http://planroom.adsmo.net/bidders.asp?job_id=6862
7. Prospective bidders contact American Document Solutions, 1400 Forum Blvd Suite 7A, Columbia MO 65201, 573-446-7768 to order official plans and specifications.

ATTACHMENTS:

1. REVISED Drawings: C-101, C-102, C-401, C-402, C-501, C-502, C-503, C504, E-400, S-001, S-102, T-400.

April 16, 2019

END ADDENDUM NO. 1